



Product Service

Attestation of Conformity

No. N8A 104798 0026 Rev. 00

Holder of Certificate: **RECOM SILLIA SAS**
4 Avenue Pierre Marzin
22300 Lannion
FRANCE

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262110405-00

Date, 2021-12-27

(David Bo)

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 104798 0026 Rev. 00

Model(s):

RCM-xxx-6MA "M2"(xxx=340-400 in step of 5W)
 RCM-xxx-6MB "M2"(xxx=285-330 in step of 5W)
 RCM-xxx-6MC "M2"(xxx=255-300 in step of 5W)
 RCM-xxx-6MD "M2"(xxx=230-265 in step of 5W)
 RCM-xxx-6MZ "M2"(xxx=170-200 in step of 5W)
 RCM-xxx-6MF "G1"(xxx=380-425 in step of 5W)
 RCM-xxx-6ME "G1"(xxx=320-355 in step of 5W)
 RCM-xxx-6MF(xxx=425-455 in step of 5W)
 RCM-xxx-6ME(xxx=355-380 in step of 5W)
 RCM-xxx-6MM(xxx=390-415 in step of 5W)
 RCM-xxx-7MF(xxx=535-550 in step of 5W)
 RCM-xxx-7MM(xxx=490-500 in step of 5W)
 RCM-xxx-7ME(xxx=445-455 in step of 5W)
 RCM-xxx-7MG(xxx=400-410 in step of 5W)
 RCM-xxx-8MM(xxx=635-665 in step of 5W)
 RCM-xxx-8ME(xxx=580-605 in step of 5W)
 RCM-xxx-8MG(xxx=520-545 in step of 5W)

Black series:

RCM-xxx-6MA-BB "M2"(xxx=340-400 in step of 5W)
 RCM-xxx-6MB-BB "M2"(xxx=285-330 in step of 5W)
 RCM-xxx-6MC-BB "M2"(xxx=255-300 in step of 5W)
 RCM-xxx-6MD-BB "M2"(xxx=230-265 in step of 5W)
 RCM-xxx-6MZ-BB "M2"(xxx=170-200 in step of 5W)
 RCM-xxx-6MF-BB "G1"(xxx=380-425 in step of 5W)
 RCM-xxx-6ME-BB "G1"(xxx=320-355 in step of 5W)
 RCM-xxx-6MF-BB(xxx=425-455 in step of 5W)
 RCM-xxx-6ME-BB(xxx=355-380 in step of 5W)
 RCM-xxx-6MM-BB(xxx=390-415 in step of 5W)
 RCM-xxx-7MF-BB(xxx=535-550 in step of 5W)
 RCM-xxx-7MM-BB(xxx=490-500 in step of 5W)
 RCM-xxx-7ME-BB(xxx=445-455 in step of 5W)
 RCM-xxx-7MG-BB(xxx=400-410 in step of 5W)
 RCM-xxx-8MM-BB(xxx=635-665 in step of 5W)
 RCM-xxx-8ME-BB(xxx=580-605 in step of 5W)
 RCM-xxx-8MG-BB(xxx=520-545 in step of 5W)
 xxx is standing for rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790



Product Service

Attestation of Conformity

No. N8A 104798 0026 Rev. 00

**Tested
according to:**

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06

Page 3 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.